



INTERNATIONAL JOURNAL OF ADVANCE RESEARCH, IDEAS AND INNOVATIONS IN TECHNOLOGY

ISSN: 2454-132X

Impact factor: 4.295

(Volume 3, Issue 6)

Available online at www.ijariit.com

Technique to Stabilize Inorganic and Colloidal Particle Present in Raw Water

Umakant

Azad Institute of Engineering and
Technology, Lucknow, Uttar Pradesh
umakantchaurasiya9984@gmail.com

Mirza Mohsin Beg

Azad Institute of Engineering and
Technology, Lucknow, Uttar Pradesh
mirzamohsinbeg0786@gmail.com

Abdullah Khan

Azad Institute of Engineering and
Technology, Lucknow, Uttar Pradesh
umakantchaurasiya9984@gmail.com

Samshad Khan

Azad Institute of Engineering and
Technology, Lucknow, Uttar Pradesh
umakantchaurasiya9984@gmail.com

Maaz Allah Khan

Azad Institute of Engineering and
Technology, Lucknow, Uttar Pradesh
umakantchaurasiya9984@gmail.com

Abstract: Techniques and various kinds of methods are used for stabilizing the contents like mineral and another organic compound which are present in the water need to be removed through this process which is performed. Raw water which is also a pure form of water needs to be stabilized through a various process which can be made safe for consumption.

Keywords: Stabilize Inorganic, Colloidal Particle, Raw Water.

INTRODUCTION

Until 1970 underground water was the main source of water for both drinking and irrigation purposes. As a result, almost all aquifers were seriously depleted form over pumping with the coastal aquifers suffering from sea intrusion.

The increase of population as well as the increase in the tourist and industrial activities have led to an increase in the demand for water and have created an acute shortage of potable water.

The relevant Authorities identified the water shortage problem in time and in consultation with international Organisations, prepared a long term plan for solving the problem.

Convincing evidence of the great significance which was given and continues to be given to the rational exploitation of the water resources is the present storage capacity of the dams and ponds etc.



INORGANIC AND COLLOIDAL PARTICLE IN RAW WATER

Raw water is natural water found in the environment and has not been treated, nor have and minerals, ions, particles or living organisms been removed. Raw water includes rainwater, ground water, water from infiltration wells, and water from bodies like lakes and rivers. Without treatment, raw water can be used for farming, construction or cleaning purpose.

(1) Farmers use it for watering their crops or give to livestock to drink, storing it in man-made lakes or reservoirs for long periods of time. Construction industries can use raw water for making cement or for damping down unsealed roads to prevent dust rising.

WHAT'S INCLUDED IN A BASIC RAW WATER TREATMENT SYSTEM?

As mentioned above, the exact components of a raw water treatment system depend on the quality of water being drawn from in relation to the quality of water needed. But in general, a basic raw water treatment system typically includes some type of:

- Chemical feed to help facilitate the flocculation or coagulation of any suspended solids.
- Clarifier to settle out the larger solids.
- Filtration to remove the smaller particles.

WATER TREATMENT PLANTS

GENERAL PRINCIPLES TREATMENT STAGES

Water treatment plants surface water from the dams. Raw water contains suspended and inorganic material, plant material, Bacteria, aeration of water.



Removal of superadded matter. Decolourisation and oxidization of the inorganic material and the killing of all pathogenic micro-organisms by adding chlorine (prechlorination)

1. Removal of Suspended Mater

Suspended matter present in the water like leaves, water plants, soil etc. is retained at the raw reservoir of the treatment plant.

2. Pre Chlorination

Chlorine has oxidizing and disinfecting properties. With the addition of chlorine the various organic and inorganic materials like iron, hydrogen sulphide etc. are oxidized and all the pathogenic and other micro-organisms are killed or inactivated.

Chlorine is present at all stages of water treatment in order ensure that there is no development of pathogenic micro-organisms.

3. Flocculation

Addition of Aluminum Sulphate: The mixture of aluminum Sulphate is necessary in order to remove the organic particles present in the raw water and to change the color of the water from green to clear, the aluminum Sulphate Acts the colloidal particles of the water and flocks are formed. As these flocks are heavier than the water molecules, they gradually settle down to the bottom of the reservoir as sludge.

4. Sedimentation

After the addition of aluminum Sulphate and polyelectrolyte the flocks down, as sludge, in the sedimentation tanks. The sedimentation tanks are sometimes called clarifiers because here. The water is being clarified. The removed of sludge is done on a daily basis and the sludge is transferred to the sludge drying beds, while the water is transferred to the filters.

5. Filtering

After the sedimentation tanks, the water passes through special rapid sand filters where it is filtered in order to remove all the remaining flocks/particles which are present in the water.

The filters are washed at regular time intervals, by flashing water in the opposite direction, in order to keep clean and in good operation.



6. Addition of Lime

In Lime add to the water to correct its acidity (pH). The addition of lime is done, only when considered necessary, usually during the winter months. The processes of lime addition.

The raw water coming from the dams of Cyprus is alkaline (pH) 8.0-8.5 but after the addition of aluminum sulphate and chlorine it becomes more and (pH 7.0-7.5).

7. Post Chlorination

After the water treatment process is completed, chlorine is again add in the water to ensure that there is no growth of any pathogenic micro-organisms in the water supplied to the water boards etc.

Coagulation (Water Treatment)

In water treatment, coagulation is a process that occurs when a coagulant is added to water to “destabilize” colloidal suspensions conversely. Flocculation involves the addition of polymers that clump the small, destabilized particles together into larger aggregates so that they can be more easily separated from the water. Coagulation is a chemical process that involves neutralization of charge whereas flocculation is a physical process can be used as a preliminary or intermediary step between other water or wastewater treatment processes like filtration and sedimentation. Iron and aluminum salts are the zirconium have been found to be highly effective as well

- Factors
- Mechanism
- Determining Coagulant Dose

TERSEPHANOU WATER TREATMENT PLANT

Tersephanou Water Treatment Plant has been in operation since October 1999. The nominal capacity of the Plant is 60 000 cubic meters per day with provision for extension for an extension to 90 000 cubic metros per day. The Plants treats raw water from the Kouris and Kalavassos dams through the Southern Conveyor pipeline. Desalinated water from the Dhekelia Desalination Plant can also be conveyed to Nicosia through the Tersephanou pumping station and the Tersephnou-Nicosia conveyor. Tersephanou Water Treatment Plant Supplies water to the cities of Nicosia, Lamaca and Famagusta.

Technical Characteristics

Aeration tank.

3 sedimentation tanks with a storage capacity of 375 m³ and 833m³/h capacity.]

8 filters of 400 m³/h capacity.

16 000 m³ treated water reservoir.

SELF CONTAINED WATER TREATMENT UNITS

For the supply of additional water to the Athienou area, two self-contained water treatment units have been installed in 1996 with a nominal capacity of 250 cubic meters per day each. Units operate only during the period April to October.



DESALINATION SYSTEMS

GENERAL PRINCIPLES AND TREATMENT STAGES

Desalination systems have the ability to remove salts from sea water and produce fresh potable water. The major desalting processes are:

Thermal Distillation Processes

- Multi-stage Flash Distillation
- Multiple Effect Distillation
- Vapour Compression Distillation
- Solar Distillation

Membrane processes

- ❖ Electrodialysis
- ❖ Reverse Osmosis

a) With Energy Recovery.

b) Without Energy Recovery.

In thermal distillation processes, saline water is heated to boiling point producing vapour, which is condensed, to form fresh water. For these processes, thermal energy is required, which can be produced by conventional or by renewable sources, such as solar energy, in membrane sources, such as solar energy. In membrane processes, electricity is required, either for water compression, (70-80 atmospheres) or for ionization of the sea water salts.

REVERSE OSMOSIS PROCESS

Reverse osmosis is a membrane separation process in which water from a pressurized saline solution is separated from the solutes by flowing through a membrane. For this separation no heating or phase change is necessary. The major energy required for desalting is for pressurizing the feed water of the membranes.

The basic stages of treating sea water in a reverse osmosis system are the following.

1. Pretreatment.
2. Reverse Osmosis.
3. Post treatment.

1. Pre Treatment

In reverse osmosis systems pretreatment of sea water is very important for the membranes. Therefore. In pretreatment, stage micro-organisms must be destroyed and suspended solids must be removed so that micro-organism growth and salt precipitation do not occur on the membranes. Usually, pretreatment of saline water consists of:

- Pre chlorination of sea water
- Coagulation of colloid particles
- Fine filtration
- Acid addition (pH correction and inhibit Precipitation)

2. Reverse Osmosis

At this stage, high pressure pumps supply the pressure needed to enable the water to pass through the membranes and reject the salts. This pressure ranges from 54 to 80 atmospheres. As a portion of the water passes through the membranes. In the remaining feed water salt content increases. At the same time, a portion of this feed water is discharged without passing through the membranes. Without this controlled discharge, the pressurized water would continue to increase in salt concentration creating such problems as precipitation of supersaturated salts and increased osmotic pressure across the membranes. The amount of the feed water discharged to waste is between 20 and 70 percent of feed flow and depends on the salt content of the feed water.

3. Post Treatment

At the stage of post treatment, water is stabilized and prepared for distribution.

This stage might consist of:

- Removal of gases, such as hydrogen sulphide.
- Adjustment of pH and Hardness.

REFERENCES

1. Water Resources Systems, Planning, and Analysis” by D.P. Louck,
2. J. R. Stedinger, and D.A. Haith
3. Economics of Water Resources Planning” by L.D. James, and R.R.
4. Lee System Approach to Water Management” by A.K. Biswas
5. Water Resources Systems Modelling” by Tesfay Gebretsadkan
6. Sustainability Criteria for Water Resource Systems” by Daniel P.
7. Loucks Water Resources Systems Engineering” by W.A. Hall, and J.A. Dracup